



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

September 1, 1983

03 SEP 7 09:00

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-006/2 -
Update Report - Fire
Penetrations Opened
AECM-83/0535

This is an update to previous reports submitted on March 18, 1983, and May 17, 1983. The conditions for which the reports were submitted occurred on February 10, 1983, when fire penetrations AE-382C and AE-384C were opened to allow performance of a planned maintenance work order. Voluntary entry into Technical Specification 3.7.7 action (a) was initiated and an hourly fire watch was established. These conditions were reported pursuant to Technical Specification 6.9.2.

The maintenance work order associated with the above penetrations has been completed and the Limiting Condition for Operation was lifted on August 27, 1983. These conditions had no affect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: (See Next Page)

8309120377 830901
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

LE 22

1/0

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard
 Mr. R. B. McGehee
 Mr. T. B. Conner
 Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
 Office of Inspection & Enforcement
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555

Document Control Desk
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555