


James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342.3840

DESIGNATED ORIGINAL

Certified By *Map*



Corbin McNeill
Resident Manager

July 22, 1983
JAFP 83-0769

United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Attention: Dr. Thomas E. Murley,
Regional Administrator

Gentlemen:

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT
DOCKET NO. 50-333
ULTRASONIC TEST DATA

Enclosed is the examination data for the 22" recirculation manifold to end cap weld. The data consists of a zero degree exam plus two 45 degree exams which were done to verify the size of the indication.

Our analysis of this indication as regards to its origin and any impact on the piping structural integrity, is in progress.

Please contact Mr. David Sancic, of my staff, at Extension 203 if you have any further questions on this data.

Very truly yours,

David Sancic by direction

CORBIN A. McNEILL, JR.

CAM:DS:fah
Att.

CC: J. P. Bayne: NYPA, WPO
R. A. Burns: NYPA, WPO
R. J. Converse: NYPA, JAF
V. Childs: NYPA, JAF
J. Gray: NYPA, WPO
D. Sancic: NYPA, WPO
Document Control Center

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

8309120455 830824
PDR ADOCK 05000333
Q PDR