



ULNRC - 3126

January 10, 1995

Document Control Desk
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop P1-137
Washington, D.C. 20555

NOTIFICATION OF SNUBBER SAMPLE PLANS
REFUELING OUTAGE FUNCTIONAL TEST PROGRAM
CALLAWAY PLANT UNIT-1

- Ref.: 1) NUREG-1058, Rev. 1; Technical Specifications
Callaway Plant, Unit 1. Section 4.7.8
2) ULNRC - 1162

The referenced Technical Specification identifies the sample plans which are available to the licensee for the functional testing of plant snubbers. Per the Tech Spec, a representative sample of each snubber type will be tested during the first refueling shutdown and at least once per 18 months thereafter during shutdown. Beginning in Refuel 7, Spring 1995, Union Electric will be implementing the requirements of the functional test program as set forth below.

The installed safety-related mechanical snubbers (808) manufactured by Pacific Scientific will be tested using Plan 2 (37 Plan) as previously submitted per ULNRC - 1162. An initial sample of 37 snubbers will be functionally tested and evaluated against the acceptance criteria. The results of each day's testing will be plotted on Figure 4.7-1 until the point plotted at the end of the day falls in the "Accept" or "Reject" region, or all snubbers have been tested.


The sixteen (16) Steam Generator hydraulic snubbers will be converted to limit stop components per Plant Modification CMP 94-1001 during Refuel 7. As there will be no installed hydraulic type snubbers for the operating cycles subsequent to Refuel 7, they will be deleted from the test plan and will not be tested during Refuel 7 shutdown.

9501240328 950110
PDR ADOCK 05000483
P PDR


A001
110

ULNRC - 3162
Page 2
January 10, 1995

Any changes to the above sample plan choices by Union Electric - Callaway will be directed in writing to your office in accordance with Technical Specification 4.7.8.



C. D. Naslund, Manager
Nuclear Engineering



KWK/DLB/RLR/bjk

cc: USNRC Document Control Desk
USNRC Region III - Regional Administrator
USNRC Resident Inspector, Callaway Plant
USNRC Licensing Project Manager (2 copies)
USNRC Region III - Chief, Reactor Projects Section III A
Missouri Public Service Commission - Manager, Electric Dept.
Deputy Director, Missouri Department of Natural Resources
Shaw, Pittman, Potts & Trowbridge