



GPU Nuclear

P.O. Box 480

Middletown, Pennsylvania 17057

717-944-7621

Writer's Direct Dial Number

September 19, 1983
5211-83-266File: Licensee Event
Reports

Dr. Thomas E. Murley
Region I, Regional Administrator
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
LER 83-25

This is to confirm the telephone notification to Mr. F. Young, NRC Resident Inspector by Mr. M. A. Nelson at 1810 hrs. on September 16, 1983.

A containment isolation valve (CIV) was found open while containment integrity was required. The CIV (FS-V-405) is a 3/4" vent/test connection for the fire service supply to the Reactor Building. This event is considered reportable under section 6.9.2.a.2 of the Unit I Technical Specifications.

Although reportable, there was no threat to the health and safety of the public since the second boundary, FS-V-401 remained closed.

Investigation of the cause for this incident and the corrective actions to prevent recurrence will be described in the 14 day followup report.

Sincerely,

R. J. Toole
Operations and Maintenance
Director, TMI-1

RJT:HBS:jrg

cc: R. Conte
CARIRS

8309230340 830919
PDR ADOCK 05000289
S PDR

IE29 10