NRC FORM 366 (12-81) 10 CFR 50

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | LICENSEE CODE: C A S O S 3 (2) | LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) | LICENSE TYPE: 4 1 1 1 1 (4) | CAT (5)

CON'T 01 | REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 3 6 2 (7) | EVENT DATE: 0 8 1 1 8 3 (8) | REPORT DATE: 0 9 1 4 8 3 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With Unit 3 in Mode 3 at 0630, operators attempted to open the steam inlet valve
03 HV-4716 during a normal start of the auxiliary feedwater pump turbine. Control
04 Room instrumentation indicated that HV-4716 was not opening completely. After
05 several unsuccessful attempts to open the valve the steam-driven auxiliary feed-
06 water pump was declared inoperable and LCO 3.7.1.2, Action Statement 'a' was
07 entered and satisfied within the 72 hour limit. There was no impact on plant
08 operations or the health and safety of plant personnel or the public since both
motor-driven auxiliary feedwater pumps remained operable.

09 | SYSTEM CODE: H H (11) | CAUSE CODE: A (12) | CAUSE SUBCODE: A (13) | COMPONENT CODE: V A L V E X (14) | COMP. SUBCODE: E (15) | VALVE SUBCODE: D (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR: 8 3 | — | SEQUENTIAL REPORT NO.: 0 6 3 | / | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | — | REVISION NO.: 0

ACTION TAKEN: X (18) | FUTURE ACTION: X (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS: 0 0 0 0 (22) | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: A (25) | COMPONENT MANUFACTURER: X 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Inspection revealed that the valve had tripped closed during the pump starting.
11 The valve was reset and the steam-driven auxiliary feedwater pump was started
12 and declared operable at 1245. An engineering evaluation to determine the cause
13 of the valve trip has been initiated and results, including any required
14 corrective action will be reported in an LER revision.

15 | FACILITY STATUS: B (28) | % POWER: 0 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): Operator Observation

16 | ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

17 | PERSONNEL EXPOSURES NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

18 | PERSONNEL INJURIES NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z (42) | DESCRIPTION (43): NA

20 | PUBLICITY ISSUED: N (44) | DESCRIPTION (45): NA | NRC USE ONLY

NAME OF PREPARER H. B. RAY PHONE 714/492-7700

8309270257 830914
PDR ADOCK 05000362
S PDR

IE22

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY
STATION MANAGER

TELEPHONE
(714) 492-7700

September 14, 1983

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket No. 50-362
30-Day Report
Licensee Event Report No. 83-063
San Onofre Nuclear Generating Station, Unit 3

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating License NPF-10 for San Onofre Unit 3, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) form for an occurrence involving Limiting Condition for Operation (LCO) 3.7.1.2 associated with the Auxiliary Feedwater System. Enclosed LER 83-063 addresses this event.

If there are any questions regarding the above, please contact me.

Sincerely,

Enclosure: LER No. 83-063

IE 22
1/1

83-22

cc: A. E. Chaffee (USNRC Resident Inspector, Units 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Division of Technical Information and Document Control

Institute of Nuclear Power Operations (INPO)