

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of )

NIAGARA MOHAWK POWER CORPORATION )

Docket No. 50-410

Nine Mile Point Nuclear Station Unit 2 )

**APPLICATION FOR AMENDMENT TO OPERATING LICENSE**

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. NPF-69, hereby requests that Specification 4.8.1.1.2.e.8 of the Technical Specifications set forth in Appendix A to the license be amended. This proposed change has been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification change contained herein represents a revision to Surveillance Requirement 4.8.1.1.2.e.8 to add a footnote regarding the 24 hour functional test of diesel generators. The proposed change would permit functional testing to be performed during power operation. The proposed change will not authorize any change in the types of effluents or in the authorized power level of the facility. Supporting information and analysis which demonstrate that the proposed change involves no significant hazards considerations pursuant to 10CFR50.92 are included as Attachment B.

Wherefore, applicant respectfully requests that Appendix A to Facility Operating License No. NPF-69 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By

B. Ralph Sylvia  
B. Ralph Sylvia  
Executive Vice President - Nuclear

Subscribed and sworn to before me  
on this 21<sup>st</sup> day of October, 1994.

Linda M. Landers  
NOTARY PUBLIC

LINDA M. LANDERS  
Notary Public, State of New York  
Registration No. 4906015  
Qualified in Oswego County  
Commission Expires December 31, 1995

9410270322 941021  
PDR ADDCK 05000410  
PDR

ATTACHMENT A

NIAGARA MOHAWK POWER CORPORATION  
LICENSE NO. NPF-69  
DOCKET NO. 50-410

Proposed Change to the Technical Specifications

Replace existing page 3/4 8-10. This page has been retyped in its entirety with marginal markings to indicate changes to the text.