

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 20 00 -00 00 00 00 -00 00 34 11 11 11 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CONT

01 L 05 00 00 31 67 08 26 83 30 92 08 39

REPORT SOURCE 50 51 DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 IN THE COURSE OF AN OPERATIONS TOUR DURING UNIT STARTUP AFTER A REACTOR TRIP, A

03 BODY-TO-BONNET LEAK WAS REPORTED ON 2-CTS-121E, THE EAST CONTAINMENT SPRAY HEAT

04 EXCHANGER INLET VALVE. THE EAST TRAIN WAS REMOVED FROM SERVICE TO REPAIR THE LEAK.

05 THIS CONDITION IS NON-CONSERVATIVE WITH RESPECT TO T.S. 3.6.2.1. ACTION REQUIREMENTS

06 WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. THE WEST TRAIN REMAINED

07 OPERABLE.

08

33 S P 11 E 12 B 13 V A L V E X 14 E 15 D 16

SYSTEM CODE 9 10 CAUSE CODE 11 12 CAUSE SUBCODE 12 13 COMPONENT CODE 13 18 COMP. SUBCODE 19 20 VALVE SUBCODE 20 21

17 8 13 0 8 2 0 3 L 0

LER/RO REPORT NUMBER 21 22 SEQUENTIAL REPORT NO. 24 25 OCCURRENCE CODE 28 29 REPORT TYPE 30 31 REVISION NO. 32 33

ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER A 26 20 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

13 THE REPORTED BODY-TO-BONNET LEAK OF THE ALOYCO 10" GATE VALVE WAS REPAIRED BY

11 REPLACEMENT OF THE BONNET GASKET. INVESTIGATION COULD DETERMINE NO CAUSE FOR THE

12 REPORTED LEAKAGE. OCCASSIONAL LEAKAGE OF BODY-TO-BONNET JOINTS CANNOT BE ENTIRELY

13 AVOIDED.

14

15 C 28 0 2 0 29 NA 30 B 31 OPERATOR OBSERVATION 32

FACILITY STATUS 7 8 9 % POWER 10 11 OTHER STATUS 12 13 METHOD OF DISCOVERY 44 45 DISCOVERY DESCRIPTION 46 47

16 Z 33 Z 34 NA 35 NA 36

ACTIVITY CONTENT 7 8 9 RELEASED OR RELEASE 10 11 AMOUNT OF ACTIVITY 44 45 LOCATION OF RELEASE 46 47

17 0 0 0 37 Z 38 NA 39

PERSONNEL EXPOSURES 7 8 9 NUMBER 10 11 TYPE 12 13 DESCRIPTION 40 41

18 0 0 0 40 NA 41

PERSONNEL INJURIES 7 8 9 NUMBER 10 11 DESCRIPTION 42 43

19 0 0 0 42 NA 43

LOSS OF OR DAMAGE TO FACILITY 7 8 9 TYPE 10 11 DESCRIPTION 44 45

20 Z 44 NA 45

PUBLICITY 7 8 9 ISSUED DESCRIPTION 46 47

21 N 44 NA 45

8309270376 830920
PDR ADOCK 05000316
S PDR

NRC USE ONLY

NAME OF PREPARER ROBERT H. PIEHL PHONE: 616-465-5901