

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIIDICIC2 200-000000-00 3411111 41 5

CON'T 01 L 605000316 708213813 509120813 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

012 DURING PERFORMANCE OF THE ICE CONDENSER LOWER INLET DOORS SURVEILLANCE TEST, IT WAS
013 FOUND THAT FIVE DOORS EXCEEDED THE MAXIMUM INITIAL OPENING FORCE SPECIFICATIONS. THIS
014 EVENT WAS NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICATION 4.6.5.3.1.b. THE
015 ACTION REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS
016 OCCURRENCES OF A SIMILAR NATURE INCLUDE: 050-315/75-069, 76-001, 024, 030, 038,
017 79-028, 052, 83-002, 316/78-057, 83-056.

018 SIB 11 X 12 Z 13 XXXXXXX 14 Z 15 Z 16
17 813 01813 013 L 10 10
E13 Z19 Z20 Z21 000000 Y22 Y24 Z25 X91919

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

110 INVESTIGATION REVEALED THAT THREE (3) OF THE DOORS REQUIRED ADJUSTMENTS TO THE DOOR
111 FRAME. ONE DOOR WAS FOUND TO BE CLOSED ON A LOOSE RTD CABLE. THE CABLE WAS REMOVED
112 AND SECURED AWAY FROM THE DOOR. THE REMAINING DOOR WAS INSPECTED AND THE SEALS WERE
113 CLEANED. THE DOORS WERE RETESTED SATISFACTORILY. (SEE ATTACHED SUPPLEMENT).

114 H 28 0000 29 NA B 31 SURVEILLANCE TEST 32
115 Z 33 Z 34 NA NA 36
116 0000 37 Z 38 NA 39
117 0000 40 NA 41
118 Z 42 NA 43
119 N 44 NA 45

8309270410 830920
PDR ADDCK 05000316
S PDR

NRC USE ONLY

NAME OF PREPARER R. A. PALMER

PHONE 616-465-5901

ATTACHMENT TO LER# 83-083/03L-0

SUPPLEMENT TO CAUSE DESCRIPTION

INVESTIGATION REVEALED THAT THREE (3) OF THE DOORS REQUIRED ADJUSTMENTS TO THE DOOR FRAME. ONE DOOR WAS FOUND TO BE CLOSED ON A LOOSE RTD CABLE. THE CABLE WAS REMOVED AND SECURED AWAY FROM THE DOOR. THE REMAINING DOOR WAS INSPECTED AND THE SEALS WERE CLEANED. THE DOORS WERE RETESTED SATISFACTORILY. TO PREVENT RECURRENCE, THE APPROPRIATE PROCEDURE HAS BEEN MODIFIED TO INSURE THAT ALL DOORS ARE FREE FROM OBSTRUCTIONS AND THAT THE SEALS AND SEALING SURFACES ARE FREE FROM DEBRIS THAT COULD CAUSE BINDING FOLLOWING COMPLETION OF ICE BASKET WEIGHING/REPAIR PROJECT.