



## Nebraska Public Power District

GENERAL OFFICE  
P.O. BOX 499, COLUMBUS, NEBRASKA 68601-0499  
TELEPHONE (402) 564-8561

LQA8300223  
September 16, 1983

Director of Nuclear Reactor Regulation  
Operating Reactors Branch No. 2  
Division of Licensing  
Washington, D.C. 20555

Attention: Mr. Domenic B. Vassallo, Chief

Dear Mr. Vassallo:

Subject: "Heavy Loads" Response to NRC Request

The purpose of this letter is to respond to a request from the NRC for additional information as conveyed to the District in a telecon on September 1, 1983. Specifically, this request asked for information concerning heavy loads and was made in order to allow first phase review completion of the District's initial heavy loads submittal. The District has determined that all special lifting devices have been overload tested to at least 125 percent. In addition, the dryer/separator plug strongback was modified to upgrade it during the past outage and was retested to at least 125 percent.

If you have any questions concerning this issue, please contact me at my office.

Sincerely,

Jay M. Pilant  
Technical Staff Manager  
Nuclear Power Group

JMP/gmc:emz16/10

A033  
1/0