

ATTACHMENT 2

TECHNICAL SPECIFICATION PAGES WITH PEN AND INK CHANGES

LICENSE AMENDMENT APPLICATION  
REVISION OF CONTROL ROD MOVEMENT TEST REQUIREMENT  
HOPE CREEK GENERATING STATION  
FACILITY OPERATING LICENSE NPF-57  
DOCKET NO. 50-354

NLR-N94233  
LCR 94-33

The following Technical Specification for Facility Operating License No. NPF-57 is affected by this License Amendment Request:

<u>Technical Specification</u>	<u>Page</u>
4.1.3.1.2.b	3/4 1-5

## REACTIVITY CONTROL SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

electrically or hydraulically shall be demonstrated OPERABLE by moving each control rod at least one notch:

- Within*
- a. At least once per 7 days, and
  - b. At least once per 24 hours when any control rod is immovable as a result of excessive friction or mechanical interference.

4.1.3.1.3 All control rods shall be demonstrated OPERABLE by performance of Surveillance Requirements 4.1.3.2, 4.1.3.4, 4.1.3.5, 4.1.3.6 and 4.1.3.7.

4.1.3.1.4 The scram discharge volume shall be determined OPERABLE by demonstrating:

- a. The scram discharge volume drain and vent valves OPERABLE at least once per 18 months, by verifying that the drain and vent valves:
  - 1. Close within 30 seconds after receipt of a signal for control rods to scram, and
  - 2. Open when the scram signal is reset.