



Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT  
POST OFFICE BOX 790  
HARTSVILLE, SOUTH CAROLINA 29550

Company Correspondence

SEP 27 1983

83 SEP 30 4 9: 17

Robinson File No: 13510C

Serial: RSEP/83-1236

Mr. James P. O'Reilly  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W., Suite 3100  
Atlanta, Georgia 30303

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23  
PROMPT NOTIFICATION - HVH COOLER LEAK

Dear Mr. O'Reilly:

In accordance with Plant Technical Specification 6.9.2.a.3, the following event is reported.

At 1452 hours on September 26, 1983, a service water leak was discovered on Containment Fan Cooler HVH-2. HVH-2 was then declared inoperable at 1601 hours (breaker open), and at 1640 hours, the HVH-2 leak was isolated. The NRC was notified of this Unusual Event via the Emergency Notification System (ENS) at 1550 hours. At 1700 hours, the NRC was notified via the ENS that the Unusual Event had terminated at 1640 hours. In accordance with Technical Specification 3.3.2.2.a, operability testing of the containment spray pumps was completed at 1735 hours. Subsequently, repairs were performed, and HVH-2 was returned to service at 0630 hours on September 27, 1983. This event is considered a degradation of a containment boundary pursuant to IE Bulletin 80-24 and is reported as such.

This event was reported to Mr. G. P. Beatty, Jr., Manager - Robinson Nuclear Project Department, on September 26, 1983, and to NRC Region II on September 27, 1983.

Very truly yours,

R. E. Morgan  
General Manager  
H. B. Robinson SEG Plant

B310040516 B30927  
PDR ADOCK 05000261  
S PDR

CLW/bss

cc: G. P. Beatty, Jr.  
S. P. Weise

1/0  
OFFICIAL COPY  
IE 22