

CP&L

Carolina Power & Light Company

USNRC REGION II
ATLANTA, GEORGIA

SEP 12 48:19

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

September 6, 1983

FILE: B09-13510C
SERIAL: BSEP/83-3007

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
LICENSE NO. DPR-62
DOCKET NO 50-324

Confirmation Facsimile of an Immediately Reportable Event (2-83-83)


Dear Mr. O'Reilly:

This confirms a telephone conversation at 1530 on September 6, 1983, between Mr. R. M. Poulk and Mr A. K. Hardin, of your office, concerning a immediately reportable event per Technical Specification 6.9.1.8.b.

At approximately 2200 on September 5, 1983, while performing a weekly fire protection periodic test, it was determined that 2-FP-V39 was shut and under clearance. An investigation determined that the clearance tag on this valve was labeled for and should have been placed on 2-PWT-V5.

V39 is the fire protection supply isolation valve for the deluge system of both Unit No. 2 Reactor Building standby gas treatment trains (SBGT). An investigation determined that this valve was shut on September 1, 1983. V39 was immediately opened to restore deluge capability to the Unit No. 2 SBGTs. Preliminary investigation indicate that neither valve was labeled with valve identification tags. An investigation on this event is continuing and will be reported in the required 14-day report.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/pms/LETPS1

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8310040593 830906
PDR ADDCK 05000324
S PDR

40
IE27