



Log # TXX-95024
File # 10119
NRCB 89-01

TUELECTRIC

January 23, 1995

C. Lance Terry
Group Vice President, Nuclear

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
SUPPLEMENTAL RESPONSE FOR NRC BULLETIN NO. 89-01,
SUPPLEMENT 2: FAILURE OF WESTINGHOUSE STEAM GENERATOR
TUBE MECHANICAL PLUGS

REF: 1) Westinghouse Letter OG-94-107, dated December 30, 1994,
Summary of NRC/W/Industry Meeting on Alloy 600 Steam
Generator Mechanical Tube Plugs and WOG Recommendation
for Utility Action

Gentlemen:

In December 1994, Westinghouse notified TU Electric (Reference 1) of recent field experience with Alloy 600 thermally treated (TT) mechanical plugs that necessitated a revision to the corrosion algorithm presented in WCAP-12244, Rev. 3, "Steam Generator Tube Plug Integrity Summary Report," November 1989, for all remaining Alloy 600 TT mechanical plugs in service that had not been repaired or replaced. This report is a voluntary supplemental response to NRC Bulletin No. 89-01, Supplement 2.

In response to Reference 1, TU Electric has verified that this issue does not impact CPSES Unit 1 nor Unit 2 since all installed Alloy 600 TT mechanical plugs have been replaced in all steam generators. Therefore, this completes TU Electric's actions with respect to this issue.

270000

9501310263 950123
PDR ADOCK 05000445
Q FDR

IFB
11

TXX-95024
Page 2 of 2

If you have any questions or need additional information, please contact Ben Mays at (817) 897-6816.

Sincerely,

C. L. Terry

C. L. Terry

By: *Roger D. Walker*
Roger D. Walker
Regulatory Affairs Manager

CBC/bm
Attachment

c - Mr. L. J. Callan, Region IV
Mr. D. D. Chamberlain, Region IV
Resident Inspectors
Mr. T. J. Polich, NRR

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
Texas Utilities Electric Company)	Docket Nos. 50-445
)	50-446
(Comanche Peak Steam Electric)	License Nos. NPF-87
Station, Units 1 & 2))	NPF-89

AFFIDAVIT

Roger L. Walker being duly sworn, hereby deposes and says that he is the Regulatory Affairs Manager for TU Electric, the licensee herein; that he is duly authorized to sign and file with the Nuclear Regulatory Commission this supplemental response to NRC Bulletin 89-01, Supplement 2; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.

Roger L. Walker
Roger L. Walker
Regulatory Affairs Manager

STATE OF TEXAS)
)
COUNTY OF DALLAS)

Subscribed and sworn to before me, on this 23rd day of January, 1995.

Gayle R. Peck
Notary Public

