

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Neil S. "Buzz" Carns
Chairman, President and
Chief Executive Officer

January 27, 1995

WM 95-0016

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: Status of Westinghouse Alloy 600
Thermally Treated Steam Generator Mechanical Plugs

Gentlemen:

This letter provides the status of Westinghouse Alloy 600 Thermally Treated (TT) mechanical plugs at Wolf Creek Generating Station (WCGS). In December 1994, Westinghouse notified Wolf Creek Nuclear Operating Corporation of recent field experience with Alloy 600 TT mechanical plugs that necessitated a revision to the corrosion algorithm presented in WCAP-12444, "Steam Generator Tube Plug Integrity Summary Report," Revision 3, for all remaining Alloy 600 TT mechanical plugs in service that had not been repaired or replaced. In response to this notification, it was verified that this issue did not impact WCGS since all installed Alloy 600 TT mechanical plugs had been replaced in all steam generators. Therefore, no further action is required for this issue.

If you should have any questions regarding this submittal, please contact me at (316) 354-8831, extension 4000, or Mr. Richard D. Flannigan at extension 4500.

Very truly yours,


Neil S. Carns

NSC/jra

cc: L. J. Callan (NRC)
D. D. Chamberlain (NRC)
J. F. Ringwald (NRC)
J. C. Stone (NRC)

9502010304 950127
PDR ADDCK 05000482
P PDR

010000

P.O. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/HC/VET

Adol
1/10