



Southern California Edison Company

23 PARKER STREET
IRVINE, CALIFORNIA 92718

January 30, 1995

WALTER C. MARSH
MANAGER OF NUCLEAR REGULATORY AFFAIRS

TELEPHONE
(714) 454-4403

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Applications 137 and 121, Review Information
Technical Specification Improvement Program
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are the following items to facilitate review of two provisions of the Technical Specification Improvement Program (TSIP), Amendment Applications 137 and 121:

1. Calculation N-4072-003, Fuel Handling Accident (FHA) Inside Containment, Control Room and Offsite Doses. This calculation is used to demonstrate the acceptability of having both Containment Airlock Doors open concurrently with a fuel handling accident, to support proposed LCO 3.9.3, CONTAINMENT PENETRATIONS.
2. Markup of the *current* Technical Specifications for Section 3.9.4, CONTAINMENT BUILDING PENETRATIONS, including the provisions of *proposed* LCO 3.9.3, CONTAINMENT PENETRATIONS. This markup incorporates the provisions of TSIP into the existing Technical Specifications format.
3. An addition to the current Technical Specification Bases for Section 3.9.4, CONTAINMENT BUILDING PENETRATIONS, including the administrative provisions to be in place when both Airlock Doors are open concurrently.
4. Markup of the *current* Technical Specifications for Section 3.3.1, REACTOR PROTECTIVE INSTRUMENTATION, including the provisions of *proposed* LCO 3.3.13, SOURCE RANGE POWER MONITORING CHANNELS. This markup incorporates the provisions of TSIP into the existing Technical Specifications format. Also, this markup uses the words "source range neutron flux monitors" to be consistent with the existing Technical Specifications wording.

Inclusion of the Containment Airlock Door and Source Range Monitoring provisions into the current Technical Specifications would not alter the requirements from those proposed in PCN 299.

01004

9502020147 950130
PDR ADOCK 05000361
P PDR

ADD



Document Control Desk

-2-

If you have any questions regarding these items, please let me know.

Sincerely,

A handwritten signature in dark ink, appearing to read 'Harold C. Marsh'.

Enclosure

cc: L. J. Callan, Regional Administrator, NRC Region IV
K. E. Perkins, Jr., Director, Walnut Creek Field Office, NRC Region IV
J. A. Sloan, NRC Senior Resident Inspector, San Onofre Units 2 and 3
M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3
C. I. Grimes, Chief, NRC Technical Specifications Branch
T. R. Tjader, Review Coordinator - CEOG STS, NRC Technical
Specifications Branch
H. Kocol, California Department of Health Services