

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004
(412) 393-5206
(412) 643-8069 FAX

GEORGE S. THOMAS
Division Vice President
Nuclear Services
Nuclear Power Division

January 24, 1995

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001


**Subject: Beaver Valley Power Station, Unit No. 2
Docket No. 50-412, License No. NPF-73
NOED, Completion of Testing Requirements**

The purpose of this letter is to inform the Nuclear Regulatory Commission (NRC) of the completion of the requirements associated with the December 30, 1994, Notice of Enforcement Discretion. The NRC exercised discretion not to enforce compliance with the quarterly surveillance requirements in the Beaver Valley Unit 2 Technical Specification Table 4.3-1, Item 7, Overtemperature Delta-T (OTAT), and Item 8, Overpower Delta-T (OPAT) for the period from December 30, 1994, to January 13, 1995, at 1820 hours.

On January 10, 1995, the technical specification required channel functional testing was successfully completed on the Channel 3 OTAT and OPAT circuits. The channels were demonstrated operable three days prior to the expiration of the Notice of Enforcement Discretion. During the period of December 30, 1994, to January 10, 1995, no spikes were recorded on Channel 3 circuits.

The Duquesne Light Company appreciates the NRC's responsive reply to our request for enforcement discretion.

Sincerely,



George S. Thomas

cc: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. G. E. Edison, Sr. Project Manager

000013

9502020420 950124
PDR ADDCK 05000412
P PDR

Accol
1/10