

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

'95 JAN 30 P1:44

I-120 89 MAY 22 P3:

[Handwritten signature]

I-120

PLANT VOGTLE UNIT 2
NRC DOCKET 50-425
OPERATING LICENSE WPF-81
NRC HEARING FOR PLANT VOGTLE FULL-POWER LICENSE

Gentlemen:

In reviewing the transcript for the Vogtle Unit 2 NRC Hearing for a Full Power License, we discovered two minor areas where the record needs correcting.

On page 33 while Mr. McDonald was reviewing the hierarchy between the CEO of Georgia Power Company and the Vogtle Plant Manager, he inadvertently left out the Senior Vice President of Nuclear Operations. The organization is as described on figures 13.1.1-1 and 13.1.1-2 of the Vogtle Final Safety Analysis Report.

On page 40 while Mr. McCoy was responding to Commissioner Curtiss' concern on the pressurizer surge line stratification issue, he inadvertently stated that both Vogtle units have been analyzed and both meet the criteria of the ASME Code. In fact, only Unit 2 has been analyzed for this new concern and we are addressing Unit 1 according to the schedule specified in NRC Bulletin 88-11.

Should you have any questions or comments, please contact this office.

Sincerely,

W. G. Hairston, III
W. G. Hairston, III

JAB/gm

9502030093 950106
PDR ADOCK 05000424
G PDR

Adol
1/1

R-7
12244

NUCLEAR REGULATORY COMMISSION
50-424-02A-3
50-425-02A-3
Docket No. 120
In the matter of Georgia Power Vogtle 1 & 2
Staff ☒
Applicant ☒
Intervenor ☒
Cont'g Offt ☒
Contractor ☒
Other ☒
Reporter C. Riner
DATE 1-5-95
Witness W. George Hairston

Exhibit 120, page 1 of 1