

PALISADES PLANT
Docket 50-255

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M | T | P | A | L | I | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | | | E
7 8 9 14 15 25 26 30 37 CAT 58

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 1 | 2 | 0 | 0 | 0 | 2 | 5 | 5 | 7 | 0 | 8 | 2 | 8 | 8 | 3 | 8 | 0 | 9 | 2 | 7 | 8 | 3 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | While shutdown for refueling, a routine refueling duration surveillance re-
03 | vealed nonpredictable zero shifts in pressurizer pressure transmitters PT-
04 | 0102A and PT-0102D. The transmitter drift resulted in RPS instrument settings
05 | being less conservative than those established by Tech Specs as follows: Chan-
06 | nel "A"; TM/LP @ 1745 psia vs 1750 psia (min.). Channel "D"; High Pressurizer
07 | Pressure @ 2266 psia vs 2255 psia (max.). Reportable per TS6.9.2.b(1). No
08 | threat to public health or safety resulted.
7 8 9

09 | SYSTEM CODE | I | A | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP SUBCODE | T | 15 | VALVE SUBCODE | 2 | 16 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 | LER NO REPORT NUMBER | 8 | 3 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 6 | 2 | 24 | 25 | OCCURRENCE CODE | 1 | 0 | 3 | 27 | 28 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32 |
18 | ACTION TAKEN | X | 33 | 19 | FUTURE ACTION | C | 34 | 20 | EFFECT ON PLANT | Z | 35 | 21 | SHUTDOWN METHOD | Z | 36 | 22 | HOURS | 0 | 0 | 0 | 0 | 37 | 38 | ATTACHMENT SUBMITTED | N | 39 | 40 | NPRO-4 FORM SUB. | Y | 41 | 24 | PRIME COMP SUPPLIER | N | 42 | 25 | COMPONENT MANUFACTURER | F | 1 | 1 | 8 | 0 | 43 | 44 | 45 | 46 | 47 | 48 |
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Preliminary evaluation of the out of tolerance condition indicates that the
11 | plant was not in an unsafe condition during the preceding operating cycle.
12 | All four pressurizer pressure transmitters (Channels A-D) will be replaced
13 | during the current outage. Further analysis/evaluation of this condition
14 | with respect to safe plant operation is continuing.
7 8 9

15 | FACILITY STATUS | H | 26 | 0 | 0 | 0 | 29 | 30 | OTHER STATUS | NA | 31 | METHOD OF DISCOVERY | B | 32 | ROUTINE SURVEILLANCE TEST | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
16 | ACTIVITY RELEASED | Z | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
20 | PUBLICITY ISSUED | N | 44 | 45 | 46 | 47 | 48 | 49 | 50 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

8310120249 830927
PDR ADOCK 05000255
S PDR

IE 22



Consumers
Power
Company

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

September 27, 1983

James G Keppler, Administrator
Region III
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - LICENSEE EVENT REPORT 83-62 (PRESSURIZER PRESSURE INSTRUMENT
"AS FOUNDS" OUT OF TOLERANCE)

On the reverse please find Licensee Event Report 83-62 (Pressurizer Pressure
Instrument "As Founds" Out of Tolerance) which is reportable to the NRC per
Technical Specification 6.9.2.b(1).

Brian D Johnson
Staff Licensing Engineer

CC Director, Office of Nuclear Reactor Regulation
Director, Office of Inspection and Enforcement
NRC Resident Inspector - Palisades

SEP 29 1983

IE2211