



Carolina Power & Light Company
PO Box 10429
Southport, NC 28461

JAN 30 1995

SERIAL: BSEP 95-0041
10 CFR 50.90
TSC 93TSB07

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

BRUNSWICK NUCLEAR PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-323 & 50-324/LICENSE NOS. DPR-71 & DPR-62
WITHDRAWAL OF REQUEST FOR LICENSE AMENDMENTS AND EXEMPTION REQUEST
REGARDING INCREASING ILRT AS-FOUND LEAKAGE LIMIT

Gentlemen:

On October 19, 1993, Carolina Power & Light Company (CP&L) submitted a request for amendments to the Technical Specifications for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2 (Serial: BSEP 93-0168). The proposed amendments would increase the as-found leakage limit from .75L_a to 1.0L_a. Along with these license amendment requests, CP&L submitted a request for exemption from 10 CFR 50, Appendix J to allow the as-found leakage increase (Serial: BSEP 93-0169).

Based on forthcoming rulemaking in this area, CP&L hereby withdraws the request for license amendment and accompanying exemption request. Please refer any questions regarding this submittal to Mr. George Honma at (910) 457-2741.

Sincerely,

R. P. Lopriore
Manager - Regulatory Affairs

030102

cc: Mr. Dayne H. Brown
Mr. S. D. Ebner, Regional Administrator, Region II
Mr. C. A. Patterson, Brunswick NRC Senior Resident Inspector
Mr. D. C. Trimble, Jr., NRR Senior Project Manager - Brunswick Units 1 and 2
The Honorable H. Wells, Chairman - North Carolina Utilities Commission

9502030297 950130
PDR ADDCK 05000324
P PDR

Acc'd
1/10