



William J. Cahill, Jr.
Executive Vice President
and Chief Nuclear Officer

November 10, 1994
JPN-94-058

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Revised Proposed Technical Specification Page
Primary Containment Atmosphere Monitoring (JPTS-93-010)

- Reference:
1. NYPA letter, W. A. Josiger to NRC, "Proposed Changes to the Technical Specifications Primary Containment Atmosphere Monitoring (JPTS-93-010) (JPN-94-038)", dated August 4, 1994.
 2. NRC NUREG-1433, "Standard Technical Specifications General Electric Plants BWR/4," Revision 0, dated September 1992.

Dear Sir:

Attached is a revised page 180 from the James A. FitzPatrick Nuclear Power Plant Technical Specifications. This page replaces the proposed page 180 previously submitted as part of Reference 1. This page has been revised to include action statements associated with the operability requirements for primary containment oxygen concentration. The proposed revisions specify the actions to be taken when the primary containment oxygen concentration is not within the Technical Specification limit. These action statements are consistent with those contained in the NRC Standard Technical Specifications (Reference 2). Specifically, the proposed action statements will require restoration of the oxygen concentration to within limits within 24 hours or to reduce thermal power to less than or equal to 15% of rated within the following 8 hours.

In addition, the limiting conditions for operation have been revised to more clearly specify that the primary containment oxygen concentration should be less than four volume percent while in the Run mode, with the exceptions of the relaxations allowed during startup and shutdown.


The proposed revision to page 180 has been reviewed and approved by the Plant Operating Review Committee (PORC) and Safety Review Committee (SRC) and does not alter the conclusions of the safety evaluation contained in Reference 1.

ADD 1

In accordance with 10 CFR 50.91, a copy of this application and the associated attachments are being provided to the designated New York State official.

If you have any questions, please contact Ms. C. D. Faison.

Very truly yours,



William J. Cahill, Jr.
Executive Vice President and
Chief Nuclear Officer
Nuclear Generation

cc: Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 136
Lycoming, NY 13093

Mr. Nicola F. Conicella, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, NY 12223