

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIDICIC?200-00000-003411111415

CON'T  
REPORT SOURCE L601500031167092081381005839

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

012 DURING A SURVEILLANCE TEST ON THE SOLID STATE PROTECTION SYSTEM (TRAIN A), TWO LOGIC  
013 POSITIONS TESTED UNSATISFACTORILY. THIS AFFECTED THE REACTOR COOLANT PUMP UNDERVOLTAGE  
014 POSITION OF THE AUTOMATIC LOGIC, TECHNICAL SPECIFICATION TABLE 3.3-1 ITEM 22. AFTER  
015 THE ONE HOUR TIME LIMIT, (ACTION ITEM #1), PREPARATIONS TO BE IN HOT STANDBY WITHIN  
016 SIX HOURS WERE INITIATED. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS  
017 OCCURRENCES INCLUDE: 050-315/83-081, 81-043, 78-067 AND 50-316/83-033, 038, 047,  
018 82-056, 78-076.

019 SYSTEM CODE IB11 CAUSE CODE E12 CAUSE SUBCODE G13 COMPONENT CODE INISITIRU14 COMP SUBCODE X15 VALVE SUBCODE Z16  
LER/RO REPORT NUMBER 813 EVENT YEAR 123 SEQUENTIAL REPORT NO. 019024 OCCURRENCE CODE 0328 REPORT TYPE L30 REVISION NO. 032  
ACTION TAKEN A33 FUTURE ACTION Z34 EFFECT ON PLANT Z35 SHUTDOWN METHOD Z36 HOURS 000037 ATTACHMENT SUBMITTED N41 NPRO-4 FORM SUB. Y42 PRIME COMP. SUPPLIER N43 COMPONENT MANUFACTURER W112044

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

100 UNIVERSAL CARD A-311 (WESTINGHOUSE, PART NO. 6056D21G01) WAS FOUND TO BE DEFECTIVE.  
111 THE LOGIC CARD WAS REPLACED. THE SURVEILLANCE TEST WAS PERFORMED ON TRAIN "A" TO  
112 VERIFY SYSTEM OPERABILITY. NO FURTHER ACTION IS PLANNED.

113  
114

15 FACILITY STATUS E78 % POWER 10029 OTHER STATUS NA30 METHOD OF DISCOVERY B31 DISCOVERY DESCRIPTION SURVEILLANCE TEST32  
ACTIVITY CONTENT Z33 RELEASED OF RELEASE Z34 AMOUNT OF ACTIVITY NA35 LOCATION OF RELEASE NA36  
PERSONNEL EXPOSURES NUMBER 00037 TYPE Z38 DESCRIPTION NA39  
PERSONNEL INJURIES NUMBER 00040 DESCRIPTION NA41  
LOSS OF OR DAMAGE TO FACILITY TYPE Z42 DESCRIPTION NA43  
PUBLICITY ISSUED N44 DESCRIPTION NA45

8310140140 831005  
PDR ADOCK 05000316  
S PDR

NAME OF PREPARER R. A. PALMER

PHONE 616-465-5901

NRC USE ONLY