

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201
October 10, 1983
LOZ-83-0177

J. WILLIAMS, JR.
SENIOR VICE PRESIDENT
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J.G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e), ITEM E-35, ELECTRICAL EQUIPMENT
FOUNDATION WELDING
W.O. 57300, JOB E-5590, FILE NO. 956C,

This letter constitutes an interim report concerning the subject condition initially reported to the Commission on January 4, 1983, as a potentially reportable deficiency under the requirements of 10CFR50.55(e).

As stated in our previous letter LOZ-83-0063, dated June 28, 1983. Henry J. Kaiser Company (HJK) and The Cincinnati Gas & Electric Company indicated the need to reinspect all essential panel installations for compliance with design document requirements.

HJK has developed and approved two Construction Inspection Plans (CIPs) for the surveillance of paint removal and the inspection of the electrical panel mounting welds. HJK has been reinspecting the welds utilizing these CIP's. Foothill Electric Company (FEC) and HJK are scheduled to have the paint removal and inspection effort completed by October 28, 1983. A follow-up report will be submitted by December 1, 1983.

8310170404 831010
PDR ADOCK 05000358
S PDR

OCT 1 1983


IE2711

Mr. J.G. Keppler
Regional Administrator
October 10, 1983
LOZ-83-0177
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 
J.C. WILLIAMS, JR.
SENIOR VICE PRESIDENT

DJS/sfr

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Resident Site Supervisor
ATTN: W.M. Hill
NRC Zimmer Project Inspector, Region III
ATTN: E. R. Schweibinz