



Southern California Edison Company

23 PARKER STREET

IRVINE, CALIFORNIA 92718

November 8, 1994

WALTER C. MARSH

MANAGER OF NUCLEAR REGULATORY AFFAIRS

TELEPHONE

(714) 454-4403

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Docket Nos. 50-361 and 50-362
Special Report
San Onofre Nuclear Generating Station, Unit 3

This letter provides the 10 day special report required by Technical Specification 3.3.3.4.a of Facility Operating License NPF-10 and NPF15 for Units 2 and 3, respectively, whenever one or more of the required meteorological monitoring channels is out of service for more than 7 days.

On October 29, 1994, Edison removed the primary and secondary Meteorological towers from service for planned equipment upgrades to improve system reliability. Edison plans to complete the system upgrades and return the Meteorological towers to service by November 23, 1994. In the interim, meteorological data will be obtained from the Emergency Operations Facility meteorological tower and from National Weather Service contacts at local and regional airports.

If you have any questions, please let me know.

Sincerely,

cc: L. J. Callan, Regional Administrator, NRC Region IV
A. B. Beach, Director, Division of Reactor Projects, NRC Region IV
K. E. Perkins, Jr., Director, Walnut Creek Field Office, NRC Region IV
J. A. Sloan, NRC Senior Resident Inspector, San Onofre Units 2 & 3
M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3

010057

9411220413 941108
PDR ADOCK 05000361
S PDR

IE23
1/0