

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 N Y I P S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

1 L 0 5 0 0 0 2 4 7 0 8 2 8 8 3 0 9 2 7 8 3 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

2 While in hot shutdown, the Main Steam Isolation Valve (MS-1) for Loop 21 failed to

3 completely close during the process of isolating the secondary plant for maintenance.

4 The other three MSIV's closed (Tech. Spec. 3.4.A(5)). The health and safety of the

5 public were unaffected. Previous similar events: R.O. 74-2-24, LER 78-021,

6 82-005 and 82-021.

7

8

9 C D 11 E 12 B 13 V A L V E X 14 C 15 D 16

17 8 3 0 3 0 3 L 0

18 Z 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 A 5 8 5 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

28 MS-1-21 failed to close due to insufficient lubrication of the valve stem packing.

29 Preventive maintenance was performed on the four MSIV's. The stem packing on all four

30 valves was lubricated with nuclear grade nickel graphite anti-seize lubricant. The

31 valve was stroked and closed within the five second time limit.

32

33 G 0 0 0 NA A Operator Observation

34 Z 33 Z 34 NA NA

35 0 0 0 Z 38 NA

36 0 0 0 NA

37 Z 42 NA

38 N 44 NA

8310190163 830927
PDR ADOCK 05000247
S PDR

NRC USE ONLY

68 69

014 526 5542

91 7-928

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 463-2533

September 27, 1983


Re: Indian Point Unit No. 2
Docket No. 50-247
LER-83-033/03L-0

Dr. Thomas E. Murley,
Regional Administrator-Region I
U. S. Nuclear Regulatory Commission
531 Park Avenue
King of Prussia, Pa. 19406

Dear Dr. Murley:

The attached Licensee Event Report LER-83-033/03L-0 is hereby submitted in accordance with the requirements of Technical Specification 6.9.1.7. This event is of the type described in Technical Specification 6.9.1.7.2.b.

Very truly yours,



attach.

cc: Document Control Desk (2 copies)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Thomas Foley, Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

IE 22
11