



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

83 OCT 17 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-089/0 - Fire
Rated Door 1A203 Blocked
Open to Support Planned
Maintenance Activities
AECM-83/0650

On September 15, 1983, fire rated door 1A203 was blocked open to support planned maintenance activities. Fire watches were established in accordance with Technical Specification 3.7.7 until the door was restored on October 6, 1983.

This is submitted as a Special Report pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation (LCO) was exceeded. The event had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

L. F. Dale

for L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee

Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

8310190232 831013
PDR ADDCK 05000416
PDR
S

OFFICIAL COPY

IE 22
1/2