

6.2.3 INDEPENDENT TECHNICAL REVIEWS

A Technical Review Program shall be established, implemented and maintained to encompass the following Technical Review responsibilities.

FUNCTION

6.2.3.1 The Technical Review Program responsibilities shall encompass:

- a. NRC issuances, industry advisories, Licensee Event Reports, and other sources that may indicate areas for improving plant safety;
- b. Internal and external operating experience information that may indicate areas for improving plant safety;
- c. Plant operating characteristics, plant operations, modifications, maintenance and surveillance to verify independently that these activities are performed safely and correctly and that human errors are reduced as much as practical, and
- d. Making detailed recommendations to the Senior ~~Vice President and Chief Nuclear Officer~~ ^{Site Official} for procedure revisions, equipment modifications or other means of improving nuclear safety and plant reliability.

The Technical Review Program shall utilize ^{several} sufficient on-site personnel who are independent of the plant management chain to perform the reviews.

RECORDS

6.2.3.2 Written records of technical reviews shall be maintained. As a minimum these records shall include the results of the activities conducted, the status of recommendations made pursuant to Specification 6.3.2.1 and an assessment of company operations related to the reviews performed. *A copy of the monthly Technical Review Program report shall be provided to the Senior Site Official.*

QUALIFICATIONS

6.2.3.3 Personnel performing reviews pursuant to Technical Specification 6.2.3.1 shall have either a bachelor's degree in engineering or related science and at least 2 years professional level experience, at least 1 year of which shall be in the nuclear field, or equivalent education and experience as defined in ANSI/ANS 3.1, 1981, Section 4.1.

6.2.4 SHIFT TECHNICAL ADVISOR

6.2.4.1 The Shift Technical Advisor shall provide advisory technical support to the Control Room Commander in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the station.

6.3 TRAINING

6.3.1 A retraining and replacement licensed training program for the station staff shall be maintained under the direction of the Training Manager and shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971 and Appendix A of 10 CFR Part 55 and the supplemental requirements specified in Sections A and C of Enclosure 1 of the NRC letter dated March 28, 1980 to all licensees, and shall include familiarization with relevant industry operational experience.

ADMINISTRATIVE CONTROLS

6.2.3 INDEPENDENT TECHNICAL REVIEWS

A Technical Review Program shall be established, implemented and maintained to encompass the following Technical Review responsibilities.

FUNCTION

6.2.3.1 The Technical Review Program responsibilities shall encompass:

- a. NRC issuances, industry advisories, Licensee Event Reports, and other sources that may indicate areas for improving plant safety;
- b. Internal and external operating experience information that may indicate areas for improving plant safety;
- c. Plant operating characteristics, plant operations, modifications, maintenance and surveillance to verify independently that these activities are performed safely and correctly and that human errors are reduced as much as practical, and
- d. Making detailed recommendations to the Senior Site Official for procedure revisions, equipment modifications or other means of improving nuclear safety and plant reliability.

The Technical Review Program shall utilize several on-site personnel who are independent of the plant management chain to perform the reviews.

RECORDS

6.2.3.2 Written records of technical reviews shall be maintained. As a minimum these records shall include the results of the activities conducted, the status of recommendations made pursuant to Specification 6.3.2.1 and an assessment of company operations related to the reviews performed. A copy of the monthly Technical Review Program report shall be provided to the Senior Site Official.

QUALIFICATIONS

6.2.3.3 Personnel performing reviews pursuant to Technical Specification 6.2.3.1 shall have either a bachelor's degree in engineering or related science and at least 2 years professional level experience, at least 1 year of which shall be in the nuclear field, or equivalent education and experience as defined in ANSI/ANS 3.1, 1981, Section 4.1.

6.2.4 SHIFT TECHNICAL ADVISOR

6.2.4.1 The Shift Technical Advisor shall provide advisory technical support to the Control Room Commander in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the station.

6.3 TRAINING

6.3.1 A retraining and replacement licensed training program for the station staff shall be maintained under the direction of the Training Manager and shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971 and Appendix A of 10 CFR Part 55 and the supplemental requirements specified in Sections A and C of Enclosure 1 of the NRC letter dated March 28, 1980 to all licensees, and shall include familiarization with relevant industry operational experience.