



ENTERGY

Entergy Operations, Inc.
River Bend Station
PO Box 220
St. Francisville, LA 70775

November 21, 1994

Mr. Dale Givens
Assistant Secretary
Office of Water Resources
Louisiana Department of Environmental Quality
Water Pollution Control Division
Post Office Box 44091, Capitol Station
Baton Rouge, LA 70804-4091

Subject: Station Sewage System Leakage
Reference: Louisiana Water Discharge Permit WP0409
File No. G1.11.2
RBG: 41,073

Dear Mr. Givens:

This letter is a written follow-up for a prompt notification of a sewage leak excursion which occurred on November 16, 1994.

A leaking sewage line was discovered on November 16 at 11:30 a.m.. The subsequent investigation indicated that the leak started when a vehicle struck a capped 4-inch PVC vent/clean-out pipe connected to a sewage line serving a restroom facility in a remote building. The sewage leak eventually entered the East Creek storm drain system with an estimated flow of less than .25 gpm. At the time of the excursion no flow was observed in the storm drain with the last flow observed on November 10, 1994. The leaking sewage did not escape the River Bend property or enter the East Creek drainage.

Immediate corrective action taken included securing the restroom facility, repair of the sewage line, and lime addition over the effected area. Required sampling and analysis including fecal coliform counts will be performed at permitted Outfall 006 (East Creek) during the next rainfall.


9411300337 941121
PDR STPRG ESGLA
PDR

JE2310

Mr. Dale Givens
November 21, 1994
RBG: 41,073
Page 2 of 2

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Sincerely,



S. Keith Stoma
Coordinator Environmental (Acting)

cc: Nuclear Regulatory commission
Document Control Desk
Washington D.C. 20555

U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Resident Inspector
P.O. Box 1051
St. Francisville, LA 70775