



Entergy Operations, Inc.  
River Bend Station  
PO Box 220  
St. Francisville, LA 70775

November 21, 1994

Ms. Mary Simmons  
U.S. Environmental Protection Agency  
Region 6 - 6W-EA  
1445 Ross Avenue  
Dallas, TX 75202-2733

Subject: Station Sewage System Leakage  
Reference: NPDES Permit LA0042731  
File No. G1.11.7  
RBG: 41,074

Dear Ms. Simmons:

This letter is a written follow-up for a prompt notification of a sewage leak excursion which occurred on November 16, 1994.

A leaking sewage line was discovered on November 16 at 11:30 a.m.. The subsequent investigation indicated that the leak started when a vehicle struck a capped 4-inch PVC vent/clean-out pipe connected to a sewage line serving a restroom facility in a remote building. The sewage leak eventually entered the East Creek storm drain system with an estimated flow of less than .25 gpm. At the time of the excursion no flow was observed in the storm drain with the last flow observed on November 10, 1994. The leaking sewage did not escape the River Bend property or enter the East Creek drainage.

Immediate corrective action taken included securing the restroom facility, repair of the sewage line, and lime addition over the effected area. Required sampling and analysis including fecal coliform counts will be performed at permitted Outfall 006 (East Creek) during the next rainfall.


9411300343 941121  
PDR STPRG ESGTX  
PDR

JE23/10

Ms. Mary Simmons  
November 21, 1994  
RBG: 41,074  
Page 2 of 2

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Sincerely,



S. Keith Stoma  
Coordinator Environmental (Acting)

cc: Nuclear Regulatory commission  
Document Control Desk  
Washington D.C. 20555

U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

NRC Resident Inspector  
P.O. Box 1051  
St. Francisville, LA 70775