

Entergy Operations, Inc.
River Bend Station
5485 U.S. Highway 61
P.O. Box 220
St. Francisville, LA 70775
Tel 504 336 6225
Fax 504 635 5068

James J. Fisicaro
Director
Nuclear Safety

February 8, 1995

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Stop P1-37
Washington, DC 20555

Subject: River Bend Station - Unit 1
Docket No. 50-458
License No. NPF-47
License Amendment Request (LAR) 91-11, Removal of Component Lists
(TAC M-88872)

File Nos.: G9.5, G9.42

Reference: 1) RBG-39894, dated January 14, 1994
2) RBG-41056, dated November 10, 1994

RBFI-95-0036
RBG-41180

Gentlemen:

On January 14, 1994, Entergy Operations Inc. (EOI) submitted an application for amendment to the River Bend Station (RBS) Technical Specifications, License Amendment Request (LAR) 91-11 (Reference 1). Included were proposed changes which would remove component lists from the Technical Specifications per guidance provided in NRC Generic Letters 91-01 and 91-08. On November 10, 1994, the NRC Staff and RBS personnel discussed several clarifications to the information provided in Attachment 1 of RBG-39894. These changes addressed an NRC concern of further identifying the scope of the technical specification line item. This discussion resulted in several clarifications of individual specifications as documented in Reference 2.

As a result of further review of the application for amendment, additional clarifications of the same type have been identified and addressed in Attachment 1 to this letter. These clarifications have been discussed with RBS's NRR Project Manager. Based on these discussions, RBS recommends including these clarifications in LAR 91-11.

9502130246 950208
PDR ADDCK 05000458
P PDR


ADD 1

License Amendment Request 91-11
RBF1-95-0036
RBG-41180
February 8, 1995
Page 2 of 2

Attachment 2 contains the originally submitted Technical Specification pages marked up to reflect the clarifications. The proposed clarifications are editorial and do not impact the scope of the original submittal, therefore, they are bounded by the No Significant Hazards Considerations previously submitted in RBG-39894.

If you have any questions or comments, please contact Mr. Otto P. Bulich of my staff at (504) 336-6251.

Very truly yours,



JJF/jr
attachments

cc: Mr. David L. Wigginton
U. S. Nuclear Regulatory Commission
M/S OWFN 13-H-2
Washington, DC 20555

NRC Resident Inspector
P. O. Box 1051
St. Francisville, LA 70775

U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

PROPOSED CLARIFICATIONS TO LAR 91-11

Listed below are the proposed clarifications to LAR 91-11 based on discussions with the NRC. These clarifying changes are editorial and are bounded by the No Significant Hazards Considerations previously submitted in RBG-39894. Changes to the original submittal are noted in *italics*.

1. RBG-39894 (dated 1/14/94) Attachment 1, page 17, Section XI, SECONDARY CONTAINMENT AUTOMATIC ISOLATION DAMPERS (3/4.6.5.3)

a. Revise LCO 3.6.5.3 to read as follows:

"Each (*delete the word 'required'*) secondary containment ventilation system automatic isolation damper shall be OPERABLE."

b. Revise ACTION Statement 3.6.5.3 to read as follows:

"With one or more of the (*delete the word 'required'*) secondary containment ventilation system automatic isolation dampers inoperable, maintain at least one isolation damper OPERABLE in each affected penetration that is open and, within 8 hours, either: ..."

c. Revise Surveillance Requirement 4.6.5.3 to read as follows:

"Each (*delete the word 'required'*) secondary containment ventilation system automatic isolation damper shall be demonstrated OPERABLE: ..."