

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE: (717) 542-2181



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

October 13, 1983

Dr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-128/03L-0
ER 100450 FILE 841-23
PLA-1906

Docket No. 50-387
License No. NPF-i4

Dear Dr. Murley:

Attached is Licensee Event Report No. 83-128/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that Reactor Building Zone III (Refuel Area) pressure was less than .25 inches water gauge due to a ventilation system trip. The system and differential pressure were restored in five minutes. The trip was caused by spurious actuation of a differential pressure switch. System design is being reviewed to eliminate the cause of the spurious actuation.

H.W. Keiser
Superintendent of Plant-Susquehanna

APP/pjg

cc: G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

IE22
11