





Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

September 30, 1983

Dr. Thomas E. Murley  
Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 83-121/03L-0  
ER 100450 FILE 841-23  
PLA- 1886

Docket No. 50-387  
License No. NPF-14

Dear Dr. Murley:

Attached is Licensee Event Report No. 83-121/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b. in that during the performance of a surveillance in accordance with Technical Specification 4.2.2 during a cold startup, the Average Power Range Monitor (APRM) flow biased scram and rod block setpoints were found to be less conservative than the allowable values in Technical Specification 3.2.2. The APRM gain adjustments were calculated and implemented in accordance with Technical Specifications and station procedures.

LERs 83-007/03L-0 and 83-094/03L-0 reported similar occurrences.

H.W. Keiser  
Superintendent of Plant-Susquehanna

LAK/pjg

cc: G.G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

IE22  
11