



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

MURRAY R. EDELMAN

VICE PRESIDENT  
NUCLEAR

October 18, 1983

Mr. James G. Keppler  
Regional Administrator, Region III  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
Contact Leads on HMA Relays  
Supplied by General Electric  
[RDC 61(82)]

Dear Mr. Keppler:

This letter serves as the final report pursuant to 10CFR50.55(e) on the potential significant deficiency concerning HMA relays supplied to Perry Nuclear Power Plant by the General Electric Company (GE) for use in Unit 2. Mr. E. Riley of The Cleveland Electric Illuminating Company (CEI) originally notified Mr. P. Pelke of your office on August 18, 1982, that this potential deficiency was being evaluated by CEI. The first interim report, dated September 17, 1982, contained a description of the deficiency and the method planned for completion of the evaluation. The final report for the Unit 1 relays was contained in our letter dated November 24, 1982.

This letter contains the results of the evaluation for the Unit 2 relays.

## Evaluation of Deficiency

The inspection of the Unit 2 HMA relays was completed as required by GE Field Disposition Instruction (FDI) WPMM. The evaluation revealed no occurrences of insufficient lead to terminal spacing in the relays. This indicates the identified potential significant deficiency is not applicable to Perry's Unit 2 HMA relays.

Please call if you have any questions.

Sincerely,

*Murray R. Edelman*

Murray R. Edelman  
Vice President  
Nuclear Group

8310250483 831018  
PDR ADDCK 05000441  
S PDR

MRE:pab

cc: Mr. M. L. Childner  
NRC Site Office

Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
c/o Document Management Branch  
Washington, D.C. 20555

Records Center, SEE-IN  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339

OCT 20 1983  
IE 27  
10