

OPERATIONS NARRATIVE COOPER NUCLEAR STATION

January 1995

Cooper Nuclear Station shut down May 25, 1994 to address Emergency Diesel Generator testing deficiencies, and remained shut down for the entire month of January, 1995.

Cooper attained a unit capacity factor of 0.0 percent (MDC Net) for the month of January.

9502170040 950210
PDR ADDCK 05000298
R PDR

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	February 10, 1995
COMPLETED BY	E. A. Kernes Krause
TELEPHONE	(402) 825-5829

COMPLETED BY E. A. Kernes Krause
TELEPHONE (402) 825-5829

[illegible]

4	Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)
5	Exhibit I - Same Source

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-0298
 UNIT CNS
 DATE February 10, 1995
 TELEPHONE (402) 825-5829

MONTH January 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>		
14	<u>0</u>		
15	<u>0</u>		
16	<u>0</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

OPERATING DATA REPORT

DOCKET NO. 050-0298
UNIT CNS
DATE February 10, 1995
TELEPHONE (402) 825-5829

OPERATING STATUS

1. Unit Name: Cooper Nuclear Station Notes
2. Reporting Period: January 1995
3. Licensed Thermal Power (MWt): 2381
4. Nameplate Rating (Gross MWe): 836
5. Design Electrical Rating (Net MWe): 778
6. Maximum Dependable Capacity (Gross MWe): 787
7. Maximum Dependable Capacity (Net MWe): 764
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted, If Any (Net MWe):
10. Reasons For Restriction, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>744.0</u>	<u>744.0</u>	<u>180,481.0</u>
12. Number of Hours Reactor Was Critical	<u>0.0</u>	<u>0.0</u>	<u>133,190.2</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>0.0</u>	<u>0.0</u>	<u>131,279.3</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0.0</u>	<u>0.0</u>	<u>271,311,244.0</u>
17. Gross Electric Energy Generated (MWH)	<u>0.0</u>	<u>0.0</u>	<u>88,118,345.0</u>
18. Net Electric Energy Generated (MWH)	<u>0.0</u>	<u>0.0</u>	<u>85,098,438.0</u>
19. Unit Service Factor	<u>0.0</u>	<u>0.0</u>	<u>72.7</u>
20. Unit Availability Factor	<u>0.0</u>	<u>0.0</u>	<u>72.7</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0.0</u>	<u>0.0</u>	<u>61.7</u>
22. Unit Capacity Factor (Using DER Net)	<u>0.0</u>	<u>0.0</u>	<u>60.6</u>
23. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>8.5</u>
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>None.</u>			

25. If Shut Down At End of Report Period, Estimated Date of Startup: February 8, 1995
26. Units In Test Status (Prior to Commercial Operation):

Forecast	Achieved
INITIAL CRITICALITY	<u> </u>
INITIAL ELECTRICITY	<u> </u>
COMMERCIAL OPERATION	<u> </u>