



Northeast
Utilities System

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
(203) 665-5000

February 10, 1995

Docket No. 50-423
B15115

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station, Unit No. 3
Dynamic Rod Worth Measurement


Northeast Nuclear Energy Company (NNECO) plans to implement the Westinghouse Dynamic Rod Worth Measurement Technique at Millstone Unit No. 3 during the startup from the upcoming refueling outage. The refueling outage is scheduled to start on April 12, 1995. Westinghouse submitted WCAP-13360, "Westinghouse Dynamic Rod Worth Measurement Technique" to the NRC in May 1992 and subsequently resubmitted this WCAP as a Cost Beneficial Licensing Action on June 17, 1994.

The use of the dynamic rod worth measurement technique at Millstone Unit No. 3 will save several hours (approximately 8 to 10 hours) of critical path time during the startup of the plant. Therefore, it is requested that the review of the Westinghouse WCAP be completed by May 22, 1995, to facilitate NNECO's implementation of this rod worth methodology.

Should the NRC Staff require any additional information, please contact Mr. R. G. Joshi at (203) 440-2080.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



J. F. Opeka
Executive Vice President

cc: T. T. Martin, Region I Administrator
V. L. Rooney, NRC Project Manager, Millstone Unit No. 3
P. D. Swetland, Senior Resident Inspector, Millstone Unit
Nos. 1, 2, and 3

170052

ADD 1/0