



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Donald C. Shelton
SENIOR VICE PRESIDENT
NUCLEAR

February 13, 1995
PY-CEI/OEPA-0214L

Brian Hall
Ohio EPA
Northeast District Office
2110 E. Aurora Rd.
Twinsburg, Ohio 44087

Perry Nuclear Power Plant
OEPA Permit No. 3IB00016DD

Dear Mr. Hall,

In accordance with Part III, Section 12.c of the Permit, this letter is serving as confirmation of a telephone report of an effluent limitation exceedance made to the State Emergency Response Commission on 2/10/95.

1. The limitation which has been exceeded: The time limit (two hours) for discharge of total residual chlorine (TRC) from outfall 3IB00016004, the discharge tunnel. Free available chlorine was measured at 0.0 ppm at the final discharge point near the end of the event.
2. The extent of the exceedance: A two hour and fifteen minute discharge of TRC resulting from approximately 2 gpm of 0.8% sodium hypochlorite entering the plant service water system.
3. The cause of the exceedance: A mispositioned switch ("on" vs. "auto").
4. The period of exceedance: From 2135 to 2350 on 2/9/95.
5. The anticipated time the exceedance is expected to continue: The release was stopped at 2350 on 2/9/95.

210003

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

9502210227 950213
PDR ADDCK 05000440
S PDR

IE23
1/0

PY-CEI/OEPA-0214L
February 13, 1995
Page 2 of 2

6. Steps being taken to reduce, eliminate and/or prevent recurrence of the exceedance: A Human Performance Enhancement System evaluation is being conducted along with a detailed investigation. The results of both evaluations will be used to determine specific actions necessary to prevent recurrence.

If you have questions or require additional information, please contact Louise Barton at (216) 280-5512.

Sincerely,



for Donald C. Shelton

LKB:sc

cc: NRC Project Manager
NRC Resident Inspector
NRC Document Control Desk
NRC Region III