

The Light company

Houston Lighting & Power

South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

February 14, 1995
ST-HL-AE-4990
File No.: G26
10CFR50.73

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

South Texas Project
Unit 1
Docket No. STN 50-498
Revision 1 to Voluntary Licensee Event Report 92-018
Pressurizer Safety Valve Setpoints and
Main Steam Safety Valve Outside Required Tolerance

Pursuant to 10CFR50.73, Houston Lighting & Power Company submits the attached revision to Unit 1 Voluntary Licensee Event Report 92-018, regarding Pressurizer Safety Valve and Main Steam Safety Valve setpoints outside required tolerance. This event did not have an adverse effect on the health and safety of the public.

The purpose of this revision is to incorporate information regarding several Main Steam Safety Valve and Pressurizer Safety Valve setpoints that were found to be out of tolerance during past outages. The out of tolerance conditions of the Main Steam and Pressurizer Safety Valves were evaluated for impact to the design basis analysis. The safety analysis concluded that all criteria are met, thus, the past safety analyses bounded each situation. This revision includes an expanded safety analysis regarding out of tolerance conditions and their impact on Unit operation. Changes are indicated by revision bars.

This Licensee Event Report was originally submitted prior to the issuance of the guidance which was provided by letter from Mr. S. J. Collins, Nuclear Regulatory Commission Division Director of Reactor Safety, to Mr. W. T. Cottle, Nuclear Group Vice President, Houston Lighting & Power, dated December 8, 1993. This guidance clarified interpretation of reporting requirements related to out of tolerance conditions on primary or secondary safety relief valves. Prior to the issuance of this guidance, Houston Lighting & Power had a different interpretation of the application of this reporting requirement.

9502220127 950214
PDR ADOCK 05000498
S PDR

LER-95\92346001R1.01


Project Manager on Behalf of the Participants in the South Texas Project

JE22

The original Licensee Event Report was focused on Pressurizer Safety Valves and did not include identification of similar conditions on the Main Steam Safety Valves or prior occurrences of these conditions. Additionally, the original Licensee Event Report did not provide an evaluation of the impact of the out of tolerance condition on the design basis analysis. After analysis of the out of tolerance data, it was determined that the out of tolerance conditions experienced as a result of the Pressurizer Safety and the Main Steam Safety Valves did not result in a condition that was unanalyzed or outside the design basis of the plant.

Houston Lighting & Power will ensure that this guidance is appropriately applied to out of tolerance conditions for surveillances in future outages. Personnel have been sensitized to the analysis and reporting requirements for these type of conditions.

If you should have any questions on this matter, please contact Mr. J. M. Pinzon at (512) 972-8027 or me at (512) 972-8787



T. H. Cloninger
Vice President,
Nuclear Engineering

JMP/lf

Attachment: Revision 1 to Voluntary LER 92-018 (South Texas, Unit 1)

c:

Leonard J. Callan
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8084

Thomas W. Alexion
Project Manager
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001 13H15

David P. Loveless
Sr. Resident Inspector
c/o U. S. Nuclear Regulatory Comm.
P. O. Box 910
Bay City, TX 77404-0910

J. R. Newman, Esquire
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

K. J. Fiedler/M. T. Hardt
City Public Service
P. O. Box 1771
San Antonio, TX 78296

J. C. Lanier/M. B. Lee
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

G. E. Vaughn/C. A. Johnson
Central Power and Light Company
P. O. Box 2121
Corpus Christi, TX 78403

Rufus S. Scott
Associate General Counsel
Houston Lighting & Power Company
P. O. Box 61067
Houston, TX 77208

Institute of Nuclear Power
Operations - Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Dr. Joseph M. Hendrie
50 Bellport Lane
Bellport, NY 11713

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

U. S. Nuclear Regulatory Comm.
Attn: Document Control Desk
Washington, D. C. 20555-0001

J. R. Egan, Esquire
Egan & Associates, P.C.
2300 N Street, N.W.
Washington, D.C. 20037