

Attachment 1

Millstone Nuclear Power Station, Unit No. 3  
Proposed Revision to Technical Specifications  
Refueling Operations

Marked Up Page

February 1995

## REFUELING OPERATIONS

JAN 31 1986

### 3/4.9.2 INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

3.9.2 As a minimum, two Source Range Neutron Flux Monitors shall be OPERABLE, ~~each~~ with continuous visual indication in the control room, and one with audible indication in the containment and control room.

APPLICABILITY: MODE 6.

#### ACTION:

- a. With one of the above required monitors inoperable or not operating, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes.
- b. With both of the above required monitors inoperable or not operating, determine the boron concentration of the Reactor Coolant System at least once per 12 hours.

#### SURVEILLANCE REQUIREMENTS

4.9.2 Each Source Range Neutron Flux Monitor shall be demonstrated OPERABLE by performance of:

- a. A CHANNEL CHECK <sup>including audible counts</sup> at least once per 12 hours, ~~12~~
- b. An ANALOG CHANNEL OPERATIONAL TEST within 8 hours prior to the initial start of CORE ALTERATIONS, and
- c. An ANALOG CHANNEL OPERATIONAL TEST at least once per 7 days.

Attachment 2

Millstone Nuclear Power Station, Unit No. 3  
Proposed Revision to Technical Specifications  
Refueling Operations

Retyped Page

February 1995

## REFUELING OPERATIONS

### 3/4.9.2 INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.9.2 Two Source Range Neutron Flux Monitors shall be OPERABLE with continuous visual indication in the control room, and one with audible indication in the containment and control room.

APPLICABILITY: MODE 6.

ACTION:

- a. With one of the above required monitors inoperable or not operating, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes.
- b. With both of the above required monitors inoperable or not operating, determine the boron concentration of the Reactor Coolant System at least once per 12 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.9.2 Each Source Range Neutron Flux Monitor shall be demonstrated OPERABLE by performance of:

- a. A CHANNEL CHECK including audible counts at least once per 12 hours,
- b. An ANALOG CHANNEL OPERATIONAL TEST within 12 hours prior to the initial start of CORE ALTERATIONS, and
- c. An ANALOG CHANNEL OPERATIONAL TEST at least once per 7 days.