



Entergy Operations, Inc.
River Bend Station
5485 U.S. Highway 61
PO. Box 220
St. Francisville, LA 70775
(504) 337-6225
FAX (504) 635-5068

JAMES J. FISICARO
Director
Nuclear Safety

December 22, 1994

U.S. Nuclear Regulatory Commission
Document Control Desk
Mail Stop P1-37
Washington, D.C. 20555

Subject: River Bend Station - Unit 1
Docket No. 50-458
License No. NPF-47
Licensee Event Report 50-458/94-001-02
File Nos.: G9.5, G9.25.1.3

RBG- 41138
RBF1-94-0134

Gentlemen:

In accordance with 10CFR50.73, enclosed is a supplement to Licensee Event Report (LER) 94-001. This LER reported deficiencies in fire barrier separation in fire areas C-17 and C-24 for redundant trains of control building heating, ventilation and cooling. As corrective action for fire area C-24, a modification request was initiated to provide a means of manually operating the affected safe shutdown components from outside the fire area. However, further evaluation revealed a preferred alternative to the previously proposed corrective action. This alternative involved re-routing a cable and eliminated the need for additional operator actions. As corrective action for fire area C-17, use of the remote shutdown system as the method of shutdown for a fire in this area will be evaluated. The evaluation will be completed and, if determined necessary, a deviation request will be submitted to the NRC by 2/17/95.

Very truly yours,

JJF/jcm
enclosure

9412290139 941222
PDR ADOCK 05000458
S PDR

IFER
11

Licensee Event Report 94-001-02
December 22, 1994
RBG-41138
RBF1-94-0134
Page 2 of 2

cc: U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Resident Inspector
P.O. Box 1051
St. Francisville, LA 70775

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Mr. C.R. Oberg
Public Utility Commission of Texas
7800 Shoal Creek Blvd., Suite 400 North
Austin, TX 78757

Louisiana Department of Environmental Quality
Radiation Protection Division
P.O. Box 82135
Baton Rouge, LA 70884-2135
ATTN: Administrator