

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

OCT 02 1990

TVA-SQN-TS-90-13

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority)

Locket Nos. 50-327
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - REVISION TO TECHNICAL SPECIFICATION (TS) CHANGE
90-13 - COLD-LEG ACCUMULATOR (CLA) INSTRUMENTATION SURVEILLANCE

- References:
1. TVA letter to NRC dated May 4, 1990, "Sequoyah Nuclear Plant (SQN) - Technical Specification (TS) Change 90-13 - Cold-Leg Accumulator Instrumentation Surveillance"
 2. NRC letter to TVA dated August 11, 1989, "Emergency Amendments for Inoperable Cold Leg Injection Accumulator Level Instrumentation (TAC 74151/74152) (TS 89-37) - Sequoyah Nuclear Plant, Units 1 and 2"

In accordance with 10 CFR 50.90, we are enclosing a requested amendment to Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The proposed change supersedes the original request by Reference 1. This change modifies the CLA Instrumentation Surveillance Requirements (SR) to allow SR 4.0.3 exemption to one level and one pressure channel and deletes associated TS 3.5.1.1 action statements c and d. This change is being requested to provide an interim resolution to the issuance of a temporary change to the SQN TS as documented in Reference 2, pending NRC resolution and approval of the generic issue of Surveillance Requirements for instrumentation on accumulators.

The proposed TS 90-13 Revision is identified in Enclosure 1. The provided pages in Enclosure 1 of this letter supersede the corresponding pages provided in Enclosure 1 of Reference 1. The justification for the proposed TS 90-13 Revision is provided in Enclosure 2. The proposed TS 90-13 Revision does not alter the conclusions drawn in the Environmental Impact Evaluation or the No Significant Hazards Consideration submitted with TS 90-13 (Reference 1). Consequently, these evaluations are not resubmitted by this package.

This revision is needed in advance of the expiration of the TS 3.5.1.1 action c and d, which occurs at the restart of Unit 2 from the ongoing Cycle 4 refueling outage, scheduled to complete November 3, 1990. Accordingly, TVA requests expedited review and approval of this TS change.

9010110163 901002
PDR ADOCK 05000327
P PDC

An Equal Opportunity Employer

A001
1/1


U.S. Nuclear Regulatory Commission

OCT 02 1990

Please direct questions concerning this issue to Keith C. Weller at
(615) 843-7527.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



E. G. Wallace, Manager
Nuclear Licensing and
Regulatory Affairs

Sworn to and subscribed before me
this 2nd day of October 1990



Notary Public

My Commission Expires 11/4/92

Enclosures

cc (Enclosures):

American Nuclear Insurers
Attention: Librarian
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. S. C. Black, Deputy Director
Project Directorate II-4
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. J. N. Donohew
Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. Michael H. Mobley, Director (w/o Enclosures)
Division of Radiological Health
T.E.R.R.A. Building
150 9th Avenue, N
Nashville, Tennessee 37203

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379