



Southern California Edison Company

23 PARKER STREET
IRVINE, CALIFORNIA 92718

February 23, 1995

WALTER C. MARSH
MANAGER OF NUCLEAR REGULATORY AFFAIRS

TELEPHONE
(714) 454-4403

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Docket Nos. 50-361 and 50-362
Special Report - Inoperable Meteorological
Instrumentation
San Onofre Nuclear Generating Station, Units 2 and 3

In accordance with Technical Specification 3.3.3.4 (a) of Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, Edison is submitting this letter to report one or more channels of the meteorological monitoring instrumentation being inoperable for more than 7 days.

On February 7, 1995, the two delta temperature instrument readings began to deviate from each other and were declared inoperable. This failure was caused by electrical current leakage in outdoor signal wire connectors due to continued California winter storms. All other meteorological instrumentation remained operable.

Edison replaced the defective connectors upon the return of fair weather, and restored the delta temperature instruments to service on February 21, 1995.

If you require any additional information, please let me know.

Sincerely,

Walter C. Marsh

9503010263 950223
PDR ADOCK 05000361
S PDR

cc: L. J. Callan, Regional Administrator, NRC Region IV
A. B. Beach, Director, Division of Reactor Projects, NRC
Region IV
K. E. Perkins, Jr., Director, Walnut Creek Field Office, NRC
Region IV
M. B. Fields, NRC Project Manager, Units 2 and 3
J. A. Sloan, Senior NRC Resident Inspector, San Onofre Units
2 & 3

010043

JE22/0