



ENTERGY

Entergy Operations, Inc.

1448 S.R. 333

Russellville, AR 72801

Tel 501 858-5000

February 24, 1995

2CAN029508

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Annual Diesel Generator Data Report - 1994

Gentlemen:

Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specification 6.9.1.5.d requires an annual submittal of a diesel generator data report for the previous calendar year. This report provides the number of valid tests and the number of valid failures for each diesel generator. The purpose of this letter is to provide this information for 1994.

Seventeen (17) valid tests were conducted on the 2K-4A diesel generator with no valid failures. Seventeen (17) valid tests were also conducted on the 2K-4B diesel generator with no valid failures.

This letter completes the reporting requirements for Technical Specification 6.9.1.5.d. Should you have any questions regarding this submittal, please contact me.

Very truly yours,

for Dwight C. Mims
Director, Licensing

DCM/dwb

010030

9503010269 950224
PDR ADOCK 05000368
P PDR

ADD 1/0

cc: Mr. Leonard J. Callan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
1448 S. R. 333
Russellville, AR 72801

Mr. George Kalman
NRR Project Manager Region IV/ANO-1 & 2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852