

ATTACHMENT (I)

UNIT 2

TECHNICAL SPECIFICATIONS

MARKED-UP PAGE

3/4 6-2

### 3/4.6 CONTAINMENT SYSTEMS

#### 3/4.6.1 PRIMARY CONTAINMENT

##### Containment Leakage

#### LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of:
  1.  $\leq L_1$  (346,000 SCCM), 0.20 percent by weight of the containment air per 24 hours at  $P_1$ , 50 psig, or
  2.  $\leq L_2$  (44,600 SCCM), 0.042 percent by weight of the containment air per 24 hours at a reduced pressure of  $P_2$ , 25 psig.
- b. A combined leakage rate of  $\leq 0.50 L_1$  (173,000 SCCM), for all penetrations and valves subject to Type B and C tests when pressurized to  $P_1$ .

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION: With either (a) the measured overall integrated containment leakage rate exceeding  $0.75 L_1$  (259,500 SCCM), or  $0.75 L_2$  (33,400 SCCM), as applicable, or (b) with the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding  $0.50 L_1$ , restore the overall integrated containment leakage rate to less than or equal to  $0.75 L_1$  or less than or equal to  $0.75 L_2$ , as applicable, and the combined leakage rate for all penetrations and valves subject to Type B and C tests to less than or equal to  $0.50 L_1$  prior to increasing the Reactor Coolant System temperature above 200°F.

#### SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria, methods and provisions specified in 10 CFR Part 50, Appendix J:

- a. ~~Three~~ Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted ~~at approximately equal intervals during shutdown at either  $P_1$  (50 psig) or at  $P_2$  (25 psig), during each 10-year service period.~~

*The frequency of the Type A tests shall be in accordance with 10 CFR Part 50, Appendix J, as modified by approved exemptions.*