

1901 Chouteau Avenue
Post Office Box 149
St. Louis, Missouri 63166
314-554-2650



Donald F. Schnell
Senior Vice President
Nuclear

December 22, 1994

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

ULNRC-3119

DOCKET NUMBER 50-483
CALLAWAY PLANT
REVISION TO TECHNICAL SPECIFICATION 3/4.8.1
A.C SOURCES


Reference: ULNRC-3114, dated December 9, 1994

The referenced letter transmitted an amendment application to revise Technical Specification (T/S) Surveillance Requirement 4.8.1.1.2f.7 to remove the requirement to perform the hot restart within 5 minutes of completing the 24 hour test and place it in a separate T/S.

The purpose of this transmittal is to submit a revision to the proposed change based upon conversations between Union Electric and the NRC Staff. The areas of change consist of the following: Deleting the use of Specification 4.8.1.1.2f.6)b) for the hot restart test signal because this specification allows only the use of a simulated loss-of-offsite power in conjunction with a Safety Injection test signal to be used to auto-start the diesel generator. Also we have deleted the requirement to monitor operating temperature for stability and will rely solely on the 2 hour minimum operating time as specified in NUREG-1431 prior to performing the hot restart test.

See the attached sheets for the revised marked up page and retyped page. The conclusions in the Safety Evaluation of the original submittal are also applicable to this change.

Very truly yours,


Donald F. Schnell

JMC/plr
Attachment
9501060205 941222
PDR ADDOCK 05000483
PDR

06-11

*Acc'd
11/1*

STATE OF MISSOURI)
) S S
CITY OF ST. LOUIS)

Donald F. Schnell, of lawful age, being first duly sworn upon oath says that he is Senior Vice President-Nuclear and an officer of Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By Donald F. Schnell
Donald F. Schnell
Senior Vice President
Nuclear

SUBSCRIBED and sworn to before me this 22nd day
of December, 1994.

Barbara J. Pfaff
BARBARA J. PFAFF
NOTARY PUBLIC—STATE OF MISSOURI
MY COMMISSION EXPIRES APRIL 22, 1997
ST. LOUIS COUNTY

cc: T. A. Baxter, Esq.
Shaw, Pittman, Fotts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

M. H. Fletcher
Professional Nuclear Consulting, Inc.
18225-A Flower Hill Way
Gaithersburg, MD 20879-5334

L. Robert Greger
Chief, Reactor Project Branch 1
U.S. Nuclear Regulatory Commission
Region III
801 Warrenville Road
Lisle, IL 60532-4351

Bruce Bartlett
Callaway Resident Office
U.S. Regulatory Commission
RR#1
Steedman, MO 65077

L. R. Wharton (2)
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
1 White Flint, North, Mail Stop 13E21
11555 Pockville Pike
Rockville, MD 20852

Manager, Electric Department
Missouri Public Service Commission
P.O. Box 360
Jefferson City, MO 65102

Ron Kucera
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102