

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
MOOSEHEAD WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Seiden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 665-5000

June 14, 1991

Docket No. 50-336
B13862

Re: Inspection Report 50-336/91-16
RG 1.97

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:

Millstone Nuclear Power Station, Unit No. 2
Inspection Report 50-336/91-16
Compliance to Regulatory Guide 1.97

The NRC Staff conducted an inspection of Millstone Unit No. 2's compliance with the guidance in Regulatory Guide (RG) 1.97, "Postaccident Instrumentation," on June 10-14, 1991. During the course of that inspection, certain questions were raised which required commitments by Northeast Nuclear Energy Company (NNECO) to provide certain information to the Staff on a schedule agreed to during the inspection. The purpose of this letter is to provide those commitments.

On behalf of Millstone Unit No. 2, NNECO hereby commits to:

- o Provide the Staff with an updated submittal listing postaccident instrumentation and its status of compliance with RG 1.97 by December 15, 1991.
- o Provide the Staff with an update to the Millstone Unit No. 2 Final Safety Analysis Report as regards RG 1.97 instrumentation by April 1992.
- o Provide resolution of the cold-leg temperature instrument loops by July 15, 1991.

Current plans call for resolution of the above item by the stated date. If further research renders this date unworkable, NNECO will inform the Staff promptly.

9106190285 910614
PDR ADOCK 05000336
Q PDR


A003
110

U.S. Nuclear Regulatory Commission
B13862/Page 2
June 14, 1991

Please contact us if you have any questions.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



E. J. Mroczka
Senior Vice President

cc: T. T. Martin, Region I Administrator
G. S. Vissing, NRC Project Manager, Millstone Unit No. 2
W. J. Raymond, Senior Resident Inspector, Millstone Unit Nos. 1, 2, and 3