

BOSTON EDISON

Pilgrim Nuclear Power Station
Rocky Hill Road
Plymouth, Massachusetts 02360

George W. Davis
Senior Vice President - Nuclear

June 13, 1991
BECO 91- 77

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555


License DPR-35
Docket 50-293

Addenda to Proposed Change to the Reactor Coolant Leakage Detection Systems
Technical Specifications for the Pilgrim Nuclear Power Station

In response to a request from your staff, Boston Edison Company is providing revised pages to our April 10, 1991 proposed change to the Pilgrim reactor coolant leakage detection systems technical specification.

Specifically, in section 3.6.C.1.a.4, on page 125a, "within" is substituted for the words "averaged over" in reference to the 2gpm increase in unidentified leakage in a 24-hour period. The associated bases paragraph on page 144 is also changed accordingly.

These revised words should clarify our intent to keep within the guidelines of published NRC documents regarding reactor coolant leakage detection systems limiting conditions of operation. This change does not affect the determination of no significant hazards consideration provided in our April 10, 1991 proposal.


George W. Davis

Attachments (2)
cc: Next page
GGW/cab/5858

File

cc: Mr. R. Eaton, Project Manager
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation
Mail Stop: 1401
U. S. Nuclear Regulatory Commission
1 White Flint North
11555 Rockville Pike
Rockville, MD 20852

U. S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Senior NRC Resident Inspector
Pilgrim Nuclear Power Station