



Carolina Power & Light Company

P. O. Box 165, New Hill, North Carolina 27562
January 9, 1984

FILE: SH N-2/18
Item 146

MQAH 84-04

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400
UNMARKED BOLTS

Dear Mr. O'Reilly:

This is to confirm the January 5, 1984 telephone conversation between Mr. N. J. Chiangi (CP&L) and Mr. A. Hardin (NRC). Mr. Hardin was informed that the September 23, 1983 potentially reportable item, pertaining to bolts procured under site contract, received and installed on seismic ductwork without the ASTM A-307 Grade A marking requirement, has been evaluated and considered not to be reportable per the provisions of 10CFR50.55(e) and 10CFR, Part 21.

Thank you for your consideration in this matter.

NJC/mt

Yours very truly,

cc: Mr. R. C. DeYoung
Mr. G. Maxwell
Mr. R. L. Prevatte

N. J. Chiangi - Manager
Quality Assurance/Quality Control
Harris Plant

8401170006 840109
PDR ADOCK 05000400
S PDR

OFFICIAL COPY

JE22

1/0