



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-4-003

(412) 787-5141

(412) 923-1960

Telecopy (412) 787-2629

January 13, 1984

Mr. Harold Denton
Office of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Mr. George W. Knighton, Chief
Licensing Branch 3
Division of Licensing

SUBJECT: Beaver Valley Power Station
Docket No. 50-412
Additional Information on Cable Separation

Gentlemen:

In accordance with our statements made at a meeting held with your staff on December 20, 1983, concerning our cable separation program, we are submitting four (4) amended copies of the slides and diagrams (Attachment 1) which were utilized during the presentation and a schedule (Attachment 2) which was requested by your staff.

During the meeting, the staff questioned Duquesne Light Company as to how the spatial requirements of Regulatory Guide 1.75 was met in reference to Westinghouse electrical panels. The Westinghouse design approach with regard to separation within NSSS electrical panels has been provided and can be found in Section 7.1.2.2.1 of the FSAR which includes a reference to Westinghouse document WCAP 8892-A.

DUQUESNE LIGHT COMPANY

By E. J. Woolever
E. J. Woolever
Vice President

CLH/wjs
Attachments

SUBSCRIBED AND SWORN TO BEFORE ME THIS
15th DAY OF January, 1984.

Anita Elaine Reiter
Notary Public

ANITA ELAINE REITER, NOTARY PUBLIC
ROBINSON TOWNSHIP, ALLEGHENY COUNTY
MY COMMISSION EXPIRES OCTOBER 20, 1986

8401180151 840113
PDR ADOCK 05000412
A PDR

*Boo1
1/4
Agreement And
Dent:
Drawings
To: PM-3
Reg File-1*

COMMONWEALTH OF PENNSYLVANIA)
) SS
COUNTY OF ALLEGHENY)

On this 12th day of January, 1984, before me,
a Notary Public in and for said Commonwealth and County, personally
appeared E. J. Woolever, who being duly sworn, deposed and said that (1) he
is Vice President of Duquesne Light, (2) he is duly authorized to execute
and file the foregoing Submittal on behalf of said Company, and (3) the
statements set forth in the Submittal are true and correct to the best of
his knowledge.

Anita Elaine Reiter
Notary Public

ANITA ELAINE REITER, NOTARY PUBLIC
ROBINSON TOWNSHIP, ALLEGHENY COUNTY
MY COMMISSION EXPIRES OCTOBER 20, 1986