

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

SYSTEM CODE S D (11)		CAUSE CODE E (12)		CAUSE SUBCODE B (13)		COMPONENT CODE V A L V E X (14)				COMP. SUBCODE A (15)		VALVE SUBCODE D (16)	
7 8 9		10		11		12		13 14 15 16 17 18				19 20	
0 9													
7 8		9		10		11		12 13 14 15 16 17 18				19 20	
(17) LER/RO REPORT NUMBER		EVENT YEAR 8 3 (21) (22)		SEQUENTIAL REPORT NO. 0 4 7 (23) (24) (25) (26)		OCCURRENCE CODE 0 3 (27) (28) (29)		REPORT TYPE L (30) (31)		REVISION NO. 0 (32)			
ACTION TAKEN C (18) (19)		FUTURE ACTION Z (20)		EFFECT ON PLANT Z (21)		SHUTDOWN METHOD Z (22)		HOURS 0 0 0 0 (23) (24) (25) (26)		ATTACHMENT SUBMITTED N (27) (28) (29)		NPRD-4 FORM SUB N (30) (31)	
33 34		35 36		37 38		39 40		41 42		43 44		45 46 47	
PRIME COMP. SUPPLIER N (25)		COMPONENT MANUFACTURER G 0 8 0 (26)											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of the ball valve to stick open was due to a build-up of dry lubricant
1 1 | used in the TIP tubing. The build-up of lubricant interfered with the free movement
1 2 | of the valve. The valve was replaced on December 11, 1983, and functionally tested
1 3 | satisfactorily. There have been several failures of these valves in the past.
1 4 | The surveillance interval is adequate to detect problems of this type.

8401190297 840106
PDR ADCK 05C00254
S PDR

NEC USE ONLY

NAME OF PREPARER

J Eagle

PHONE: 309-654-2241, ext 176

IE22



Commonwealth Edison

Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242
Telephone 309/654-2241

DMB

NJK-84-9

January 6, 1984

J. Keppler, Regional Administrator
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137


Reference: Quad-Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
Appendix A, Section 3.7.D.2

Enclosed please find Reportable Occurrence Report Number (RO) 83-47/03L-0,
for Quad-Cities Nuclear Power Station.

This report is submitted to you in accordance with the requirements of
Technical Specification 6.6.B.2.b; operation in a degraded mode
permitted by a limiting condition for operation.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION


N. J. Kalivianakis
Station Superintendent

NJK:DGC/bb

Enclosure

cc B. Rybak
A. Morrongiello
INPO Records Center

JAN 12 1984

IE22 11