

Duquesne Light Company

Beaver Valley Power Station
PO Box 4
Shippensburg, PA 17077-0004

JOHN C. SIEBER
Vice President - Nuclear Group

04121 000-5256


September 30, 1991

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Proposed Operating License Change Request 191 Correction
(TAC No. 80559)

An error has been identified on Figure 3.4-2 that was submitted in the above request for Technical Specification Change. The error was in the inservice hydrostatic test temperature of 329°F stated on the figure for the criticality limit. Attached is a corrected figure with an inservice hydrostatic test temperature of 351°F. This corrected temperature is consistent with that stated in the Westinghouse report provided as a basis for the proposed Technical Specification Change and does not introduce any new or different information. Therefore, please replace the Figure 3.4-2 previously provided with the attached corrected figure.

Sincerely,


J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. DeAgazio, Project Manager
Mr. T. M. Gerusky, Director BRP/DER
Mr. R. Janati, BRP/DER
Mr. M. L. Bowling (VEPCO)