




LOUISIANA
POWER & LIGHT

142 DELARONDE STREET
P. O. BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 366-2345

January 10, 1984

W3K84-0051
Q-3-A35.07

Mr. John T. Collins
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76012



REFERENCE: Telecon C. N. Hooper (LP&L) and W. Crossman (NRC IV) on
December 8, 1983

Dear Mr. Collins:

SUBJECT: Waterford SES Unit No. 3
Docket No. 50-382
Potentially Reportable Deficiency No. 137
"Controlled Ventilation Area System (CVAS) Doors"
Final Report

On December 8, 1983, a problem with the Controlled Ventilation Area System (CVAS) Doors was reported as Potentially Reportable Deficiency No. 137. Further evaluation of the previously described condition indicates this condition is not considered reportable pursuant to the requirements of 10CFR50.55(e).

Evaluation

The reported deficiencies were discovered during planned inspections and tests, and did not involve inadequate or unapproved material, and the Control Room Leak Rate Test (SPO-46B-002) has subsequently been performed satisfactorily. In this instance, there was no chance that the design basis would not be met because of the planned inspection and testing, prior to transferring the area from the construction organization, and the design itself proved adequate. For the foregoing reasons PRD No. 137 is not considered reportable.

Very truly yours,

T. F. Gerrets
T. F. Gerrets
Quality Assurance Manager

TFG:CNH:VBR

8401230530 840110
PDR ADOCK 05000382
S PDR

13-27
1/10

Mr. John T. Collins
January 10, 1984
W3K84-0051
Page 2

cc: Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555
(15 copies)

Director
Office of Management
Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. E. L. Blake
Shaw, Pittman, Potts, & Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Mr. W. M. Stevenson
Monroe & Lemann
1424 Whitney Building
New Orleans, Louisiana 70130

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339